

废水处理运行台帐

日期	水量 (m ³)			投药量 (kg)				Pb浓度 (mg/L)			COD浓度 (mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (g/L)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/1/2	4.08	40	163.32	8558.06	26.20	5	75	3.82	0.461	0.88	55	23	0.58	1.82	8.10
2016/1/4	2.58	40	103.32	5640.54	27.30	0	50	5.46	0.459	0.92	57	26	0.54	2.20	7.80
2016/1/5	4.00	40	160.00	6029.55	18.84	5	75	3.69	0.436	0.88	56	24	0.57	2.15	8.00
2016/1/8	4.08	40	163.20	5640.54	17.28	5	75	4.46	0.427	0.90	56	28	0.50	1.90	7.50
2016/1/11	4.08	40	163.20	5835.04	17.88	0	75	2.391	0.368	0.85	55	26	0.53	2.30	7.90
2016/1/13	4.08	40	163.20	5251.54	16.09	5	75	2.616	0.201	0.92	56	23	0.59	2.05	7.80
2016/1/15	4.00	40	160.00	4084.53	12.76	0	75	2.517	0.223	0.91	54	25	0.54	2.01	8.05
2016/1/18	4.08	40	163.20	6418.55	19.66	5	75	2.384	0.287	0.88	57	24	0.58	2.15	7.89
2016/1/21	3.92	40	156.80	5835.04	18.61	0	75	3.675	0.232	0.94	55	26	0.53	2.04	8.11
2016/1/25	2.25	40	90.00	3501.03	19.45	5	25	3.464	0.386	0.89	56	23	0.59	1.93	8.05
2016/1/27	3.58	40	143.20	4668.04	16.30	0	75	3.397	0.425	0.87	54	25	0.54	2.00	7.99
2016/1/28	6.33	40	253.20	3306.52	6.53	5	100	5.173	0.385	0.93	56	23	0.59	1.89	8.00
2016/1/29	3.92	40	156.80	1556.01	4.96	5	75	4.628	0.305	0.93	55	26	0.53	1.95	7.96
2016/1/30	3.42	40	136.80	2723.02	9.95	0	75	5.217	0.369	0.93	56	23	0.59	2.01	8.06
汇总:	3.92		156.88	5101.92	17.07	3.08	71.15	3.67	0.35	0.90	55.54	24.77	0.55	2.03	7.93
	54.41		2176.24	69048.02		40.00	1000.00								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量 (kg)				Pb浓度 (mg/L)			COD浓度 (mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (g/L)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/2/2	4.00	40	160.00	3695.53	11.55	0	75	4.258	0.297	0.93	56	25	0.55	1.80	7.60
2016/2/13	4.00	40	160.00	3695.53	11.55	5	75	3.548	0.362	0.90	56	27	0.52	2.01	8.10
2016/2/18	4.00	40	160.00	6224.05	19.45	0	75	3.991	0.405	0.90	57	28	0.51	1.90	8.20
2016/2/20	2.42	40	96.68	3112.02	16.09	5	50	4.058	0.427	0.89	58	30	0.48	1.80	7.90
2016/2/24	4.00	40	160.00	5446.04	17.02	0	75	4.928	0.313	0.94	55	24	0.56	2.03	8.20
2016/2/27	1.58	40	63.32	2139.52	16.89	5	25	4.611	0.221	0.95	50	27	0.46	1.92	8.10
2016/2/29	4.00	40	160.00	7002.05	21.88	0	75	4.199	0.264	0.94	54	26	0.52	1.93	8.09
汇总:	3.43		137.14	4473.53	16.35	2.14	64.29	4.23	0.33	0.92	55.14	26.71	0.52	1.91	8.03
	24.00		960.00	31314.74		15.00	450.00								

统计:

审核:

废水处理运行台帐

日期	水量 (m ³)			投药量 (kg)				Pb浓度 (mg/L)			COD浓度 (mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (g/L)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/3/3	4.00	40	160.00	7196.55	22.49	5	75	3.494	0.352	0.90	56	25	0.55	1.80	8.10
2016/3/7	3.92	40	156.80	6613.05	21.09	0	75	3.729	0.369	0.90	56	27	0.52	2.00	7.95
2016/3/9	4.00	40	160.00	5057.04	15.80	5	75	3.664	0.233	0.94	56	25	0.55	2.10	7.50
2016/3/12	4.00	40	160.00	4473.53	13.98	0	75	3.973	0.208	0.95	54	23	0.57	1.85	7.96
2016/3/14	4.08	40	163.20	5251.54	16.09	5	100	5.533	0.214	0.96	57	26	0.54	1.85	7.85
2016/3/18	4.75	40	190.00	5640.54	14.84	5	75	2.139	0.297	0.86	55	25	0.55	2.10	7.80
2016/3/19	4.00	40	160.00	4279.03	13.37	0	75	2.828	0.23	0.92	56	28	0.50	2.11	8.00
2016/3/21	4.67	40	186.68	4279.03	11.46	5	75	3.072	0.321	0.90	58	26	0.55	2.30	7.90
2016/3/23	2.00	40	80.00	1556.01	9.73	0	50	4.401	0.448	0.90	56	27	0.52	2.05	7.80
2016/3/24	4.00	40	160.00	4084.53	12.76	5	75	4.129	0.386	0.91	54	26	0.52	2.01	8.05
2016/3/26	4.17	40	166.68	4862.54	14.59	5	75	3.57	0.228	0.94	56	27	0.52	2.10	8.40
2016/3/28	4.00	40	160.00	5057.04	15.80	5	75	3.435	0.263	0.92	57	26	0.54	1.89	7.80
2016/3/30	3.83	40	153.32	5251.54	17.13	0	75	4.196	0.383	0.91	54	24	0.56	2.30	8.10
汇总:	3.96		158.21	4892.46	15.32	3.08	75.00	3.70	0.30	0.91	55.77	25.77	0.54	2.04	7.94
	51.42		2056.68	63601.98		40.00	975.00								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (g/h)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/4/1	4.00	40	160.00	4668.04	14.59	0	75	5.266	0.213	0.96	56	27	0.52	1.82	7.86
2016/4/2	2.67	40	106.68	2723.02	12.76	5	50	2.978	0.247	0.92	55	26	0.53	1.90	8.00
2016/4/5	4.08	40	163.20	5640.54	17.28	0	75	4.48	0.298	0.93	58	30	0.48	2.00	7.95
2016/4/7	6.00	40	240.00	8558.06	17.83	5	125	3.544	0.153	0.96	55	28	0.49	2.10	7.50
2016/4/9	4.00	40	160.00	5835.04	18.23	5	75	3.712	0.176	0.95	57	26	0.54	1.82	7.96
2016/4/11	4.92	40	196.80	7391.06	18.78	0	75	3.925	0.217	0.94	59	28	0.53	1.85	7.90
2016/4/13	4.00	40	160.00	5057.04	15.80	5	75	4.021	0.162	0.96	54	23	0.57	2.20	7.80
2016/4/15	4.92	40	196.80	6418.55	16.31	5	100	4.755	0.09	0.98	57	26	0.54	1.98	8.03
2016/4/16	2.92	40	116.80	3890.03	16.65	0	50	2.312	0.112	0.95	55	25	0.55	1.90	7.50
2016/4/19	3.83	40	153.20	6029.55	19.68	5	75	2.336	0.271	0.88	56	28	0.50	2.03	8.05
2016/4/20	2.40	40	96.00	5057.04	26.34	0	50	3.844	0.452	0.88	58	26	0.55	2.10	8.40
2016/4/22	4.33	40	173.20	7002.05	20.21	5	75	3.351	0.491	0.85	59	28	0.53	2.10	7.50
2016/4/26	4.00	40	160.00	6613.05	20.67	5	75	6.212	0.333	0.95	54	23	0.57	1.82	7.96
2016/4/28	4.08	40	163.20	6807.55	20.86	0	75	5.412	0.418	0.92	57	26	0.54	1.85	7.90
汇总:	4.01		160.42	5760.24	18.28	2.86	75.00	4.01	0.26	0.93	56.43	26.43	0.53	1.96	7.88
	56.15		2085.88	81690.61		40.00	#####								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)		投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH		
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (kg/m ³)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/5/4	5.33	40	213.20	6613.05	15.51	5	75	4.436	0.259	0.94	56	27	0.52	1.82	7.86
2016/5/6	4.60	40	184.00	6029.55	16.38	0	75	5.886	0.282	0.95	55	26	0.53	1.90	8.00
2016/5/9	4.67	40	186.80	5835.04	15.62	5	75	5.154	0.325	0.94	58	30	0.48	2.00	7.95
2016/5/11	4.67	40	186.80	5640.54	15.10	0	75	4.616	0.336	0.93	55	28	0.49	2.10	7.50
2016/5/14	4.75	40	190.00	5835.04	15.36	5	75	7.149	0.429	0.94	57	26	0.54	1.82	7.96
2016/5/16	5.08	40	203.20	6613.05	16.27	5	75	6.376	0.443	0.93	59	28	0.53	1.85	7.90
2016/5/19	4.75	40	190.00	6029.55	15.87	0	75	4.337	0.324	0.93	54	23	0.57	2.20	7.80
2016/5/21	4.67	40	186.80	5446.04	14.58	5	75	3.348	0.367	0.89	57	26	0.54	1.98	8.03
2016/5/23	4.92	40	196.80	6224.05	15.81	5	75	5.361	0.445	0.92	55	25	0.55	1.90	7.50
2016/5/26	4.67	40	186.80	5640.54	15.10	0	75	4.852	0.189	0.96	56	28	0.50	2.03	8.05
2016/5/28	4.83	40	193.20	5835.04	15.10	5	75	7.73	0.314	0.96	58	26	0.55	2.10	8.40
2016/5/31	6.50	40	260.00	7002.05	13.47	5	100	4.469	0.367	0.92	59	28	0.53	2.10	7.50
汇总:	4.95		198.13	6061.96	15.35	3.33	77.08	5.31	0.34	0.93	56.58	26.75	0.53	1.98	7.87
	59.44		2164.40	72743.55		40.00	925.00								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (g/L)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/6/1	4.08	40	163.20	5640.54	17.28	5	75	5.625	0.415	0.93	56	27	0.52	1.82	7.86
2016/6/3	4.25	40	170.00	5835.04	17.16	0	75	4.727	0.218	0.95	55	26	0.53	1.90	8.00
2016/6/6	4.25	40	170.00	5835.04	17.16	5	75	3.12	0.253	0.92	58	30	0.48	2.00	7.95
2016/6/8	4.17	40	166.80	5446.04	16.33	0	75	4.498	0.314	0.93	55	28	0.49	2.10	7.50
2016/6/13	4.17	40	166.80	5640.54	16.91	5	75	6.278	0.413	0.93	57	26	0.54	1.82	7.96
2016/6/15	4.25	40	170.00	5835.04	17.16	0	75	3.062	0.417	0.86	59	28	0.53	1.85	7.90
2016/6/18	4.25	40	170.00	6029.55	17.73	5	75	4.244	0.397	0.91	54	23	0.57	2.20	7.80
2016/6/20	4.17	40	166.80	5640.54	16.91	0	75	4.596	0.372	0.92	57	26	0.54	1.98	8.03
2016/6/23	4.25	40	170.00	5446.04	16.02	5	75	3.857	0.308	0.92	55	25	0.55	1.90	7.50
2016/6/25	4.00	40	160.00	5835.04	18.23	0	75	7.24	0.476	0.93	56	28	0.50	2.03	8.05
2016/6/27	4.25	40	170.00	6224.05	18.31	5	75	5.281	0.351	0.93	58	26	0.55	2.10	8.40
2016/6/29	4.33	40	173.20	5835.04	16.84	0	75	6.048	0.317	0.95	59	28	0.53	2.10	7.50
汇总:	4.20		168.07	5770.21	17.17	2.50	75.00	4.88	0.35	0.92	56.58	26.75	0.53	1.98	7.87
	50.42		1853.60	69242.52		30.00	900.00								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (1/3)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/7/2	4.17	40	166.80	5446.04	16.33	5	75	3.471	0.253	0.93	56	25	0.55	1.79	7.90
2016/7/4	6.83	40	273.20	7002.05	12.81	0	100	3.372	0.276	0.92	57	26	0.54	1.90	8.10
2016/7/6	4.00	40	160.00	5251.54	16.41	5	75	4.097	0.144	0.96	54	24	0.56	2.10	8.01
2016/7/9	4.17	40	166.80	5640.54	16.91	0	75	4.326	0.196	0.95	55	26	0.53	1.91	7.50
2016/7/11	4.17	40	166.80	5446.04	16.33	5	100	4.111	0.375	0.91	54	23	0.57	1.82	8.10
2016/7/13	4.17	40	166.80	5251.54	15.74	0	75	6.245	0.431	0.93	55	25	0.55	2.20	7.80
2016/7/16	4.33	40	173.20	5835.04	16.84	5	75	4.095	0.388	0.91	56	27	0.52	2.15	8.00
2016/7/18	4.25	40	170.00	6029.55	17.73	5	100	4.392	0.354	0.92	55	26	0.53	1.90	7.50
2016/7/20	4.42	40	176.80	5640.54	15.95	0	75	3.995	0.237	0.94	58	30	0.48	2.30	7.90
2016/7/23	6.50	40	260.00	6807.55	13.09	5	100	6.042	0.325	0.95	55	28	0.49	2.05	7.80
2016/7/25	3.75	40	150.00	5057.04	16.86	0	75	3.945	0.336	0.91	57	26	0.54	2.01	8.05
2016/7/27	4.00	40	160.00	5640.54	17.63	5	75	2.556	0.433	0.83	59	28	0.53	2.10	8.40
2016/7/30	6.50	40	260.00	7196.55	13.84	0	100	2.003	0.409	0.80	57	27	0.53	1.89	7.80
汇总:	4.71		188.49	5864.97	15.88	2.69	84.62	4.05	0.32	0.91	56.00	26.23	0.53	2.01	7.91
	61.26		2283.60	76244.57		35.00	#####								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量 (kg)				Pb浓度 (mg/L)			COD浓度 (mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (1 / 3)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/8/1	4.17	40	166.80	5640.54	16.91	5	75	3.274	0.345	0.89	55	24	0.56	1.09	7.90
2016/8/3	4.08	40	163.20	5640.54	17.28	0	75	2.456	0.234	0.90	57	26	0.54	1.90	8.10
2016/8/6	3.92	40	156.80	5446.04	17.37	5	75	4.863	0.241	0.95	55	23	0.58	1.80	7.40
2016/8/8	4.08	40	163.20	5251.54	16.09	0	75	6.46	0.419	0.94	57	26	0.54	1.91	7.50
2016/8/10	4.33	40	173.20	5835.04	16.84	5	75	6.462	0.473	0.93	56	24	0.57	1.77	8.10
2016/8/13	3.58	40	143.20	5640.54	19.69	0	75	8.274	0.431	0.95	56	28	0.50	2.20	7.80
2016/8/15	4.07	40	162.80	5446.04	16.73	5	75	4.152	0.244	0.94	55	26	0.53	2.10	7.94
2016/8/18	4.33	40	173.20	5640.54	16.28	0	75	4.507	0.39	0.91	56	23	0.59	1.90	7.60
2016/8/20	3.83	40	153.20	5446.04	17.77	5	75	4.589	0.493	0.89	54	25	0.54	2.30	7.80
2016/8/22	4.25	40	170.00	5251.54	15.45	5	75	4.638	0.483	0.90	57	24	0.58	2.05	7.80
2016/8/24	4.33	40	173.20	5446.04	15.72	0	75	5.932	0.459	0.92	56	25	0.55	2.01	8.05
2016/8/27	4.25	40	170.00	5640.54	16.59	5	75	7.273	0.375	0.95	59	28	0.53	2.10	8.40
2016/8/29	4.33	40	173.20	5446.04	15.72	0	75	2.415	0.378	0.84	54	26	0.52	1.90	7.80
2016/8/31	4.08	40	163.20	5446.04	16.69	5	75	3.362	0.415	0.88	58	24	0.59	2.30	8.10
汇总:	4.12		164.66	5520.85	16.80	2.86	75.00	4.90	0.38	0.91	56.07	25.14	0.55	1.95	7.88
	57.63		2138.40	77217.08		40.00	#####								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	均碱量 (1/3)	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/10/5	4.33	24	103.92	3800.00	10.97	2	50	5.625	0.215	0.96	54	27	0.50	1.79	7.90
2016/10/7	4.42	24	106.08	4150.00	11.74	2	50	4.727	0.218	0.95	56	29	0.48	1.90	8.10
2016/10/8	4.08	24	97.92	4200.00	12.87	2	50	3.12	0.253	0.92	55	24	0.56	2.10	8.01
2016/10/10	4.25	24	102.00	3900.00	11.47	2	50	4.498	0.214	0.95	61	26	0.57	1.91	7.50
2016/10/12	3.83	24	91.92	4050.00	13.22	2	50	6.278	0.213	0.97	60	23	0.62	1.82	8.10
2016/10/14	4.00	24	96.00	4300.00	13.44	2	50	3.062	0.217	0.93	53	28	0.47	2.20	7.80
2016/10/15	4.00	24	96.00	3900.00	12.19	2	50	4.244	0.197	0.95	52	31	0.40	2.15	8.00
2016/10/17	4.17	24	100.08	4100.00	12.29	2	50	4.596	0.172	0.96	55	27	0.51	1.90	7.50
2016/10/19	4.08	24	97.92	3800.00	11.64	2	50	3.857	0.208	0.95	56	25	0.55	2.30	7.90
2016/10/20	3.75	24	90.00	4200.00	14.00	2	50	7.24	0.176	0.98	58	30	0.48	2.05	7.80
2016/10/22	4.17	24	100.08	3700.00	11.09	2	50	5.281	0.251	0.95	55	24	0.56	2.01	8.05
2016/10/24	3.92	24	94.08	4300.00	13.71	2	50	6.048	0.217	0.96	50	27	0.46	2.10	8.40
2016/10/26	4.17	24	100.08	3950.00	11.84	2	50	3.592	0.208	0.94	57	28	0.51	1.89	7.80
2016/10/28	3.75	24	90.00	3800.00	12.67	2	50	5.170	0.192	0.96	53	25	0.53	2.30	8.10
2016/10/29	3.92	24	94.08	3650.00	11.64	2	50	4.620	0.271	0.94	56	23	0.59	2.10	7.60
2016/10/31	3.58	24	85.92	3950.00	13.79	2	50	5.390	0.235	0.96	60	24	0.60	2.34	7.98
汇总:	4.09		96.63	3984.38	12.41	2.00	50.00	4.83	0.22	0.95	55.69	26.31	0.53	2.05	7.91
	64.42		1442.16	63750.00		32.00	800.00								

统计:

审核:

废水处理运行台帐

日期	水量(m ³)			投药量(kg)				Pb浓度(mg/L)			COD浓度(mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	重金属捕捉剂	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/11/1	8.00	23	184.00	2812	10.00	3	50	4.83	0.387	0.92	54	24	0.56	1.79	7.90
2016/11/3	8.00	23	184.00	2713	10.00	3	50	6.178	0.406	0.93	55	26	0.53	1.80	7.75
2016/11/5	8.00	23	184.00	2624	10.00	3	50	3.145	0.277	0.91	54	23	0.57	1.80	7.90
2016/11/7	8.00	23	184.00	2513	10.00	3	50	11.877	0.204	0.98	55	25	0.55	2.00	8.00
2016/11/9	8.00	23	184.00	2726	10.00	3	50	8.334	0.086	0.99	56	27	0.52	1.80	7.90
2016/11/11	8.00	23	184.00	2428	10.00	3	50	4.908	0.265	0.95	55	26	0.53	1.82	7.86
2016/11/12	8.00	23	184.00	2329	10.00	3	50	5.069	0.191	0.96	58	30	0.48	1.90	8.00
2016/11/14	8.00	23	184.00	2726	10.00	3	50	6.975	0.015	1.00	55	28	0.49	2.00	7.95
2016/11/16	8.00	23	184.00	2522	10.00	3	50	5.279	0.013	1.00	57	26	0.54	2.10	7.50
2016/11/18	8.00	23	184.00	2420	10.00	3	50	4.258	0.229	0.95	59	28	0.53	1.82	7.96
2016/11/19	8.00	23	184.00	2721	10.00	3	50	3.548	0.357	0.90	57	27	0.53	1.85	7.90
2016/11/21	8.00	23	184.00	2857	10.00	3	50	3.991	0.315	0.92	56	25	0.55	2.20	7.80
2016/11/23	8.00	23	184.00	2751	10.00	3	50	4.058	0.205	0.95	57	26	0.54	1.98	8.03
2016/11/25	8.00	23	184.00	2553	10.00	3	50	4.928	0.279	0.94	56	27	0.52	1.90	7.50
2016/11/26	8.00	23	184.00	2426	10.00	3	50	2.139	0.366	0.83	57	27	0.53	2.03	8.05
2016/11/28	8.00	23	184.00	2429	10.00	3	50	2.828	0.289	0.90	58	25	0.57	2.05	7.80
2016/11/30	8.00	23	184.00	2339	10.00	3	50	3.072	0.226	0.93	57	26	0.54	1.83	7.35
汇总:	8.00	23.00	184.00	2581.71	10.00	3.00	50.00	5.02	0.24	0.94	56.24	26.24	0.53	1.92	7.83
	136.00		3128.00	43889	170.00	51.00	850.00								

统计:

审核:

废水处理运行台帐

日期	水量 (m ³)			投药量 (kg)				Pb浓度 (mg/L)			COD浓度 (mg/L)			pH	
	T(h)	Q(m ³ /h)	水量	NaOH	里金属捕砷剂	PAM	PAC	原水	中水	去除率	原水	中水	去除率	原水	中水
2016/12/1	8.00	23	184.00	2715	10.00	3	50	3.251	0.22	0.93	52	26	0.50	1.96	8.01
2016/12/3	8.00	23	184.00	2514	10.00	3	50	4.695	0.266	0.94	54	27	0.50	1.83	7.86
2016/12/5	8.00	23	184.00	2326	10.00	3	50	3.421	0.339	0.90	53	24	0.55	1.75	7.84
2016/12/7	8.00	23	184.00	2720	10.00	3	50	4.192	0.237	0.94	52	26	0.50	1.84	7.90
2016/12/9	8.00	23	184.00	2418	10.00	3	50	2.14	0.375	0.82	53	26	0.51	1.98	7.85
2016/12/10	8.00	23	184.00	2720	10.00	3	50	3.194	0.391	0.88	52	24	0.54	1.96	7.83
2016/12/12	8.00	23	184.00	2570	10.00	3	50	3.96	0.24	0.94	51	25	0.51	1.89	7.96
2016/12/14	8.00	23	184.00	2427	10.00	3	50	5.39	0.223	0.96	50	23	0.54	2.07	8.07
2016/12/16	8.00	23	184.00	2396	10.00	3	50	3.227	0.247	0.92	54	25	0.54	2.02	7.85
2016/12/17	8.00	23	184.00	2710	10.00	3	50	5.688	0.364	0.94	52	24	0.54	1.86	8.12
2016/12/19	8.00	23	184.00	2655	10.00	3	50	5.611	0.316	0.94	51	24	0.53	1.98	8.13
2016/12/21	8.00	23	184.00	2489	10.00	3	50	3.909	0.302	0.92	50	27	0.46	1.76	7.86
2016/12/23	8.00	23	184.00	2817	10.00	3	50	2.102	0.159	0.92	49	26	0.47	1.73	8.05
2016/12/24	8.00	23	184.00	2715	10.00	3	50	3.455	0.394	0.89	53	23	0.57	1.65	8.07
2016/12/26	8.00	23	184.00	2511	10.00	3	50	3.658	0.225	0.94	56	26	0.54	1.86	8.00
2016/12/27	8.00	23	184.00	2632	10.00	3	50	4.116	0.216	0.95	54	26	0.52	1.96	8.04
2016/12/29	8.00	23	184.00	2857	10.00	3	50	3.696	0.327	0.91	54	24	0.56	1.84	7.83
2016/12/31	8.00	23	184.00	2829	10.00	3	50	3.584	0.205	0.94	57	25	0.56	1.68	8.12
汇总:	8.00	23.00	184.00	2612.28	10.00	3.00	50.00	3.85	0.28	0.92	52.61	25.06	0.52	1.87	7.97
	144.00		3312.00	47021	180.00	54.00	900.00								

统计:

审核: